

# **Independent review of distribution network feeder category definitions**

An independent review of distribution network feeder  
category definitions for the Utilities Commission

**October 2012**



**ACIL Tasman**

Economics Policy Strategy

## **ACIL Tasman Pty Ltd**

ABN 68 102 652 148

Internet [www.aciltasman.com.au](http://www.aciltasman.com.au)

### **Melbourne (Head Office)**

Level 4, 114 William Street  
Melbourne VIC 3000

Telephone (+61 3) 9604 4400  
Facsimile (+61 3) 9604 4455  
Email [melbourne@aciltasman.com.au](mailto:melbourne@aciltasman.com.au)

### **Brisbane**

Level 15, 127 Creek Street  
Brisbane QLD 4000  
GPO Box 32  
Brisbane QLD 4001

Telephone (+61 7) 3009 8700  
Facsimile (+61 7) 3009 8799  
Email [brisbane@aciltasman.com.au](mailto:brisbane@aciltasman.com.au)

### **Canberra**

Level 2, 33 Ainslie Place  
Canberra City ACT 2600  
GPO Box 1322  
Canberra ACT 2601

Telephone (+61 2) 6103 8200  
Facsimile (+61 2) 6103 8233  
Email [canberra@aciltasman.com.au](mailto:canberra@aciltasman.com.au)

### **Perth**

Centa Building C2, 118 Railway Street  
West Perth WA 6005

Telephone (+61 8) 9449 9600  
Facsimile (+61 8) 9322 3955  
Email [perth@aciltasman.com.au](mailto:perth@aciltasman.com.au)

### **Sydney**

Level 20, Tower 2 Darling Park  
201 Sussex Street  
Sydney NSW 2000  
GPO Box 4670  
Sydney NSW 2001

Telephone (+61 2) 9389 7842  
Facsimile (+61 2) 8080 8142  
Email [sydney@aciltasman.com.au](mailto:sydney@aciltasman.com.au)

## **For information on this report**

Please contact:

Jeremy Tustin

Telephone (03) 9604 4411

Mobile (0421) 053 240

Email [j.tustin@aciltasman.com.au](mailto:j.tustin@aciltasman.com.au)

## **Contributing team members**

Simon Sagerer

Tammy Read

## Contents

<b>1</b>	<b>Introduction</b>	<b>4</b>
<b>2</b>	<b>Distribution networks – service standard regulation</b>	<b>6</b>
2.1	Service quality for a distribution business – reliability of supply	6
2.2	Regulating reliability of supply	7
2.3	Segmenting performance targets	8
2.3.1	National level	9
2.3.2	Victoria	10
2.3.3	South Australia	11
2.3.4	Tasmania	12
2.3.5	Queensland	13
2.3.6	New South Wales	15
2.3.7	AER approach	16
2.4	Comparing performance with other jurisdictions	17
2.5	Conclusion – how feeders <i>should</i> be categorised	18
<b>3</b>	<b>Feeder categorisation and the Northern Territory</b>	<b>20</b>
3.1	Whether PWC has applied the feeder categorisation correctly	25
3.2	Alternative approach to feeder categorisation	25
3.2.1	Re-align feeder categories by altering threshold value	26
3.2.2	Categorise feeders as radial or meshed	27
3.2.3	Set performance targets for identified geographic locations	28
3.3	Recommended approach – a hybrid	28
<b>4</b>	<b>The available data</b>	<b>30</b>
<b>5</b>	<b>Application of feeder categories</b>	<b>34</b>
5.1	Categorise areas in the Territory	34
5.2	Determine which zones each feeder supplies	34
5.3	Select the threshold value	39
<b>6</b>	<b>Conclusion and recommendations</b>	<b>50</b>
<b>Appendix A</b>	<b>Compiled feeder categorisations</b>	<b>A-1</b>
<b>List of figures</b>		
Figure 1	Darwin – feeder categorisation and population density	21
Figure 2	Katherine – feeder categorisation and population density	22
Figure 3	Tennant Creek – feeder categorisation and population density	23
Figure 4	Alice Springs – feeder categorisation and population density	24
Figure 5	‘Fit’ between categorisations with different thresholds	39



**ACIL Tasman**

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

Figure 6	<b>Darwin – recommended feeder categorisation and population density</b>	46
Figure 7	<b>Katherine – recommended feeder categorisation and population density</b>	47
Figure 8	<b>Tennant Creek – recommended feeder categorisation and population density</b>	48
Figure 9	<b>Alice Springs – recommended feeder categorisation and population density</b>	49

### List of tables

Table 1	<b>Feeders with full set of data</b>	32
Table 2	<b>Target feeder categorisations</b>	36
Table 3	<b>PWC definition matched target definition – no further analysis</b>	41
Table 4	<b>Feeders recommended to be re-categorised as urban</b>	42
Table 5	<b>Mixed feeders</b>	42
Table 6	<b>Feeders with incomplete data</b>	43
Table 7	<b>Mismatched feeders</b>	43
Table 8	<b>Recommended feeder categories</b>	44
Table A1	<b>Type table title here</b>	A-1

# 1 Introduction

The Utilities Commission (the Commission) is the independent industry regulator for the Northern Territory (the Territory). It has various responsibilities in the energy, water and sewerage industries. Those responsibilities include regulating the electricity transmission and distribution networks in the Darwin-Katherine, Alice Springs and Tennant Creek regions (the regulated networks).

Electricity supply in the Territory is characterised by Government-owned and vertically integrated generation and transmission and distribution networks. Power and Water Corporation (PWC) is the monopoly operator of the electricity generators and networks in the Territory. Electricity retailing is dominated by PWC, although it has recently been opened to competition and two licences have been issued to other retailers.

Much of the Commission's current work stems from the Territory Government's approval, in 2009, of a reform program to strengthen regulatory oversight of the regulated industries (including electricity) in the Territory. The Commission's projects under that reform program are wide ranging. They include a review of Electricity Standards of Service for the Territory. Standard of Service in the electricity supply industry is governed by the Commission's Electricity Standards of Service Code, which took effect in 2006 (original Code).

The Commission is in the process of revoking the original Code and has been consulting on replacing it with the "Northern Territory of Australia Electricity Standards of Service Code" (the draft Code).

In the draft Code, the Commission proposes that reporting and targets for distribution network reliability performance should be segmented by feeder category. The feeder categories are defined in the draft Code.

Consistent with PWC's submission to the draft Code, the Commission initially proposed to base the feeder category definitions in the draft Code on the same definitions that have been used for distribution network performance reporting around Australia for some time.

However, PWC's recent application of the categories to its networks has revealed that parts of the Territory that would otherwise be considered urban are defined as rural (short). This was an unintended consequence in light of which the Commission is seeking to ascertain whether the application of standard feeder categories is consistent with the objectives of the draft Code.

In particular, the Commission is concerned that the presence of so many rural feeders in areas it regards as urban areas may affect the reliability performance target levels set for each feeder category and any like-for-like comparisons with other Australian distribution networks.

In this report ACIL Tasman has revisited the application of the standard feeder categories to the regulated networks. Three issues were considered:

1. whether the feeder categories have been properly applied or whether the issues the Commission has identified has resulted from error;
2. whether having feeders categorised as 'Rural short' supplying areas that would normally be considered to be 'Urban' has any implications for regulation of service performance in the Territory; and
3. whether adjustments to the feeder category definitions can be made to address those implications.

The remainder of this report is structured as follows.

Section 2 provides an overview of standard of service regulation and the way it is applied to electricity distributors in Australia.

Section 3 provides an overview of electricity networks in the Territory and a more detailed description of the Commission's concern.

Section 4 provides a brief overview of the data used in conducting this analysis.

Section 5 contains our review of PWC's application of the feeder categories to the regulated networks and our analysis of the possibility that the standard feeder categories could be redefined to address the misalignment identified by the Commission.

Section 6 provides a conclusion and recommendation.

## 2 Distribution networks – service standard regulation

Electricity distribution networks in Australia are, without exception, monopolies. This means that, unlike almost every other market in Australia, consumers are unable to choose who ‘their’ electricity distributor will be. It also means that electricity distributors are not subject to competitive forces when they set the price and quality of the distribution services they provide.

As competition between them is not possible, electricity distributors in Australia are subject to economic regulation. This approach is primarily concerned with the price(s) an electricity distributor may charge, or the revenue it may earn. However, to prevent regulated businesses from cutting reliability and quality of supply to improve profitability, price regulation is usually accompanied by service standard regulation. This forms an important part of the ‘regulatory bargain’ that a regulator strikes with a regulated business on behalf of customers.

### 2.1 Service quality for a distribution business – reliability of supply

Electricity distribution businesses ‘deliver’ electricity. The key distinction between ‘high’ and ‘low’ quality electricity distribution services is the frequency and duration of supply interruptions (blackouts). This is known as the reliability of supply.<sup>1,2</sup>

Supply interruptions are infrequent in Australian electricity systems and the vast majority of Australian electricity customers enjoy highly reliable electricity supply.

However, supply interruptions still occur. Most of those that do occur are caused on distribution networks.

From a technical perspective the frequency and duration of supply interruptions could be reduced by investing in more network infrastructure. However, this is costly.

---

<sup>1</sup> There are also other aspects of service quality, such as a distribution business’ responsiveness to customer calls. The focus of this report is on reliability of supply, so these other aspects are not discussed.

<sup>2</sup> This report focuses on feeders, which are a component of an electricity distribution network. Therefore, the term ‘supply interruptions’ in this report refers only to interruptions caused on the distribution network, supply interruptions caused by generation and transmission network issues are excluded.

The cost of providing improvements in reliability of supply must be traded off against the benefit received, taking into account the number of customers who will receive that benefit and the value they place on improved reliability of supply.

## **2.2 Regulating reliability of supply**

Reliability (and other measures of supply quality<sup>3</sup>) is regulated using an incentive based approach.

In this approach a regulator does not specify which improvements the distribution business should (or should not) make. Rather, the regulator creates a system of incentives, often financial bonuses and penalties, intended to encourage the distribution business to provide customers with optimal reliability of supply.

A service standard regime for electricity distribution generally consists of two components:

1. average standards for frequency and duration of outages, supply quality and customer service, some of which may be coupled with a financial incentive to improve service over time or penalty for failing to achieve a target level of service
2. a Guaranteed Service Level (GSL) scheme, designed to compensate individual customers who receive an unacceptable level of service.

S-factor schemes may or may not be accompanied with a financial incentive.<sup>4</sup> GSL schemes routinely include a payment to customers who do not receive the guaranteed level of service.

Between them, average service standards and GSL schemes give electricity distributors an incentive to ensure that, while the service experienced by individual customers will vary, the average level of service is satisfactory and, at the same time, no individual customer experiences service that is far below that average target level.

---

<sup>3</sup> See footnote 1.

<sup>4</sup> We understand from the Commission that it has decided not to proceed with a financial incentive scheme for average reliability performance. The Commission considers that PWC is not ready and that it would be premature to apply this type of scheme in the 2014-19 network price determination. It is understood that there will be no other penalty/reward in relation to network performance other than the GSL scheme. For readability, in this report we refer to regulating reliability of supply as a generic reference to regimes including either an s-factor or GSL scheme or both.



Another approach that is used, either with these two methods or on its own, is reporting. Some jurisdictions require electricity distributors to report reliability performance at the individual feeder level for the worst performing feeders.

As discussed in the previous section, it is optimal for a distribution business to invest in improving reliability of supply where the benefit of doing so (to customers) is greater than the cost of the investment

It follows from this that a service standard regime should encourage a distribution business to make investments to improve reliability that meet this test or, in other words, investments that are economically justified. Therefore, the targets for s-factor schemes and the guaranteed service levels for GSL schemes should be set with regard to the cost of providing improvements and customers' willingness to pay for those improvements.

## 2.3 Segmenting performance targets

It is common for electricity distribution networks to be described as if they are a single, homogeneous unit. Performance is often reported and compared at the network level, which assumes that all customers connected to the network receive the same level of service.

In practice, though, networks are not homogeneous. A network consists of a series of feeders that are all connected to one another. The performance of the network is the aggregate of the performance of each feeder, which varies feeder by feeder depending on local conditions, whether the feeder is part of a meshed or radial network, the feeder's length, the number of customers it supplies and other factors.

Distribution networks typically consist of two broad types of feeders:

- meshed feeders, which are characterised by multiple redundant elements
- radial feeders, which are characterised by few, if any, redundant elements.

Regardless of the nature of the network that supplies a particular customer, or group of customers, improving service standards is costly. However, the cost of providing improved service varies substantially for different types of feeders. In particular, it can be much more costly (in absolute terms) to make improvements in reliability of supply on radial as opposed to meshed feeders.

Furthermore, given that radial feeders typically supply fewer customers per kilometre (km) of feeder length than meshed feeders, the cost of improving service on a per customer basis on radial feeders can be substantially higher than the corresponding cost on meshed feeders.

Targets for reliability of supply (or other service standards<sup>5</sup>) could be set across groups of feeders that are characterised by a significantly different cost of providing improvements in reliability of supply (on a per customer basis). If this approach is taken, the targets will tend to be:

- more stringent than economically justifiable for feeders with high ‘cost to improve’, generally radial feeders on the edge of the network; and
- less stringent than economically justifiable for feeders with low ‘cost to improve’, generally meshed feeders in the middle of the network.

Therefore, a ‘one size fits all’ approach to applying reliability standards would typically result in targets that are ‘dragged down’ by the performance that can reasonably be achieved on the (radial) fringe of the network. These average targets would not reflect the reliability experienced by those customers supplied by feeders in the meshed part of the network. Nor would it reflect the reliability of supply for which those customers are willing to pay (as a group).

Over time a ‘one size fits all’ approach to applying reliability standards may lead to deterioration in the service standards experienced by the majority of customers.

To prevent this, regulators in most Australian jurisdictions have service standards to reflect the nature of the network in different places. This has been achieved by applying different reliability standards to different feeders.

Rather than assigning performance targets to individual feeders, which would be administratively cumbersome, reliability standards have typically been applied to groups of feeders.

This raises the question of which feeders should be grouped together and which separated. In other words, how feeders should be categorised.

The approach taken in different Australian jurisdictions is discussed in sections 2.3.1 to 2.3.7 below.

### **2.3.1 National level**

Feeders were first categorised by Victoria’s Office of the Regulator General (ORG). The ORG determined that feeders should be divided into four categories, defined as follows:

1. CBD – a feeder supplying predominantly commercial, high-rise buildings, supplied by a predominantly underground distribution network containing significant interconnection and redundancy when compared to urban areas.

---

<sup>5</sup> See footnote 1

2. Urban - a feeder, which is not a CBD feeder, with actual maximum demand over the reporting period per total feeder route length greater than 0.3 MVA/km.
3. Rural short - a feeder which is not a CBD or urban feeder with a total feeder route length less than 200 km.
4. Rural long - a feeder which is not a CBD or urban feeder with a total feeder route length greater than 200 km.

These four feeder categories were later adopted by the Steering Committee on National Regulatory Reporting Reform (SCONRRR).

When the feeder categories were adopted, SCONRRR noted that they were not widely supported. However, with a desire for national consistency and no common theme to the alternative proposals, SCONRRR had no practical alternative.<sup>6</sup>

Distribution networks were not regulated at the national level at that time, so, while the SCONRRR feeder categories were adopted nationally, this was for national reporting purposes only. Service standard regulation was managed by individual State regulators.

This began to change with the inception of the Australian Energy Regulator (AER) in 2007. The AER's approach is discussed in section 2.3.7.

### 2.3.2 Victoria

Since 2001, the Essential Services Commission (ESC) has been responsible for regulating Victoria's distribution and retail energy markets, taking over from the ORG.<sup>7</sup> The establishment of the ESC coincided with the introduction of full retail contestability for domestic and small business customers. In preparation for full retail contestability, the ORG put in place a suite of regulatory protections and, since then, the ESC has amended the regulatory framework, including new guidelines concerning service standards.

---

<sup>6</sup> SCONRRR, "National regulatory reporting for electricity distribution and retailing businesses", March 2002, p. 7, available at <http://www.accc.gov.au/content/index.phtml/itemId/332190/fromItemId/3894>, accessed 17 July 2012

<sup>7</sup> Review of Regulatory Instruments: Stage 1 Final Decision October 2008 <http://www.esc.vic.gov.au/getattachment/1bdc8bfa-4f68-4cde-8982-d56a9193117d/Review-of-Regulatory-Instruments-Stage-1-Final-Dec.pdf>

Victorian electricity distributors work to a set of average supply reliability targets based on the SCONRRR feeder categories. They also operate under a GSL scheme which applies equally regardless of feeder category.<sup>8</sup>

Electricity distributors are held to an Electricity Distribution Code which requires that reporting against targets is based on the SCONRRR feeder categories.<sup>9,10</sup>

### 2.3.3 South Australia

In 2003, the Essential Services Commission of South Australia (ESCOSA) adopted the SCONRRR feeder categories for reporting purposes, albeit with some modifications to take account of the limitations of ETSA Utilities' data (namely line lengths were approximations and load estimates were not necessarily up to date).

Service standards have never been set by reference to the SCONRRR categories in South Australia.<sup>11</sup> Rather, in conjunction with ETSA Utilities, ESCOSA undertook an analysis of three years of historical reliability performance data (2000/01 to 2002/03) to assess the degree of volatility within and across the thirteen development regions identified at the time by ETSA Utilities and to form a view on the degree to which it would be reasonable to combine some regions in order to reduce this volatility.

The outcome was to reduce the number of regions from thirteen to seven which were considered to provide a reasonable representation of differences in reliability performance across the State while eliminating more extreme variations arguably attributable to random, severe weather events.

Reliability of supply targets were set for each of these seven regions and these formed the basis of the service standard regime. ETSA Utilities was also required to report its performance against the SCONRRR feeder categories for the purpose of national comparison.

<sup>8</sup> Essential Services Commission Electricity Distribution Code January 2011  
<http://www.esc.vic.gov.au/getattachment/a6b85585-af03-4a2e-bb17-dfff74bbd886/Electricity-Distribution-Code-January-2011.pdf>

<sup>9</sup> Electricity Distribution Code May 2012 Version 7  
<http://www.esc.vic.gov.au/getattachment/c2697e4e-d485-4b6d-a5a5-11149fa3b3df/Electricity-Distribution-Code-May-2012.pdf>

<sup>10</sup> Electricity Distribution Code May 2012 Version 7  
<http://www.esc.vic.gov.au/getattachment/c2697e4e-d485-4b6d-a5a5-11149fa3b3df/Electricity-Distribution-Code-May-2012.pdf>

<sup>11</sup> South Australian Electricity Distribution Service Standards 2010 -2015 Final Decision  
<http://www.escosa.sa.gov.au/library/100617-ServiceStandards2010-2015-FinalDecision.pdf>

ESCOSA faced a similar issue in South Australia as does the Commission in the Northern Territory. The strict application of the SCONRRR categories to ETSA Utilities' network would have resulted in approximately 85 feeders (or 110,000 customers) previously classified as urban being reclassified as rural, due to their load density being less than 0.3 MVA per km.<sup>12</sup> ETSA Utilities individually assessed each of the potential "abnormal" feeders and applied a "commonly accepted notion" of urban versus rural.

ETSA Utilities' submission to ESCOSA's draft decision for the 2010-15 determination of service standards reinforced its reluctance to use the regional approach to reliability reporting and its preference for using the SCONRRR categories alone. Notwithstanding this, ESCOSA's Final Decision for the 2010-2015 regulatory period was that reliability of supply standards:

will continue to be applied on the basis of the seven regions presently established under the Electricity Distribution Code, with an enhanced reporting regime to be established for reporting on performance on the [SCONRRR feeder categories].

### 2.3.4 Tasmania

The approach taken by the Office of the Tasmanian Energy Regulator (OTTER) to distribution performance and reliability standards represents a significant departure from the SCONRRR approach. It is not based on the nature of the distribution network, but on the community that it serves.

This approach was developed by matching standards to the nature of the individual community, the value of electricity supply reliability to the community, and the cost of providing this level of reliability.

In January 2008, OTTER set distribution network reliability standards for Tasmania through a process of determining the boundaries of geographic regions (those that may have different performance standards from neighbouring regions) of which 101 were identified.<sup>13</sup> It then grouped these regions into the following five categories:

1. critical infrastructure;
2. high density commercial;
3. urban;
4. higher density rural; and

---

<sup>12</sup> See footnote 12

<sup>13</sup> The proposed regions have been classified based on electricity consumption density per unit area. *The ability of Aurora Energy to relate sales data to connection points within its geographical information system (GIS) has enabled this approach. In taking this approach, the working group has assumed that in areas where electricity use is higher, reliability will consequently have a higher value. The working group noted that, in reality, the value of reliability is highly variable within areas, between different consumers and even between times of day.*

## 5. lower density rural.

These regions and categories were developed by a working group made up of representatives from OTTER, Aurora Energy (Aurora) and the Office of Energy Planning and Conservation and were based on the following design principles:<sup>1415</sup>

- that it is equitable to have different reliability standards for distinctly different types of communities;
- that like communities should receive like levels of supply reliability;
- that current average performance is generally acceptable to the community in relation to the community's willingness to pay for improved reliability, noting that there exist areas of poor performance;
- that communities receiving a level of supply reliability lower than that appropriate for the nature of that community should be individually recognised by the standards; and
- that there exists a minimum level of supply reliability that an electricity distributor should provide to all customers.

Despite this approach to the determination of reliability standards, similarly to ETSA Utilities in South Australia, Aurora continues to report performance against the SCONRRR feeder categories for national comparison.<sup>16</sup>

### 2.3.5 Queensland

In May 2001, the Queensland Competition Authority (QCA) noted that the quality and quantity of available data was not sufficient to enable an effective service quality regime to be put in place.<sup>17</sup>

<sup>14</sup> Joint Working Group Final Report Distribution Network Reliability Standards Volume I – Summary of Recommendations and Overview.  
[http://www.economicregulator.tas.gov.au/domino/otter.nsf/LookupFiles/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf/\\$file/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf](http://www.economicregulator.tas.gov.au/domino/otter.nsf/LookupFiles/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf/$file/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf)

<sup>15</sup> The second volume of the Joint Working Group Final Report contains more technical details on the methodology employed in relation to the above, including the way in which the maps were developed.

<sup>16</sup> Joint Working Group Final Report Distribution Network Reliability Standards Volume I – Summary of Recommendations and Overview.  
[http://www.economicregulator.tas.gov.au/domino/otter.nsf/LookupFiles/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf/\\$file/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf](http://www.economicregulator.tas.gov.au/domino/otter.nsf/LookupFiles/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf/$file/R%20-%20Dx%20Standards%2007%20Final%20Report%20v1.0%20Volume%201.pdf)

<sup>17</sup> Final Determination Regulation of Electricity Distribution May 2001  
<http://www.qca.org.au/files/ACF895.pdf>

To address this, the QCA introduced a comprehensive service quality reporting and monitoring regime for the 2001-2005 regulatory period. The intention was that this would support the development of an appropriate incentive regime for the next regulatory period. Electricity distributors were required to report specific service quality measures which would support the development of an appropriate regime in the next regulatory period.

Service quality data were segmented by classifying feeders according to whether they served a CBD, Urban or Rural area using the SCONRRR feeder categories.

The QCA also sought a method of segmenting service quality data, stating service quality measures need to not only reflect the performance of the electricity distributor, but also the basic geographic and demographic characteristics of the region. Its objective was to allow a comparison with distribution systems with broadly similar characteristics.

In its Final Determination Regulation of Electricity Distribution of April 2005<sup>18</sup>, the QCA noted the difficulty experienced in developing a set of service quality incentives in 2001 due to the lack of available and comparable service quality data for distributors. A number of service quality initiatives were announced and the QCA released its decision on a service quality incentive scheme to be incorporated into the regulatory arrangements commencing 1 July 2005. This scheme was to be based on a regulatory contract with each distributor and targeting specific service quality outcomes to be achieved by the end of the next regulatory period.

In 2008, the AER published its framework and approach paper for Qld electricity distributors in November 2008, in which it stated that it would apply its Service Target Performance Incentive Scheme for Electricity Distribution Network Service Providers (STPIS) in the next regulatory period (2010-2015).

When the application of the STPIS was imminent, Ergon Energy sought increased capital expenditure for a feeder improvement program to meet it.<sup>19</sup>

However, the AER did not consider that this increased capital expenditure was necessary or prudent. It maintained that Ergon Energy's forecast reliability and quality improvement capital expenditure should remain at current regulatory period levels in the final decision.<sup>20</sup>

---

<sup>18</sup> <http://www.qca.org.au/files/ACF14.pdf>

<sup>19</sup> Ergon Energy, *Revised regulatory proposal*, January 2010.

<sup>20</sup> Queensland Final Distribution Decision, 2011 – 2015, pg 119.  
<http://www.aer.gov.au/sites/default/files/Queensland%20distribution%20decision.pdf>



In its Final Decision for the current period, the AER has set STPIS targets based on the SCONRRR classification of feeders with adjustments made on an individual distributor basis which require steady improvements in the reliability of supply provided by Energex and Ergon Energy.

### 2.3.6 New South Wales

The New South Wales Minister for Energy (the Minister) is responsible for the design, reliability and performance licence conditions for electricity distributors operating in New South Wales.

The Independent Pricing and Regulatory Tribunal (IPART) is the independent regulator that determines the maximum prices that can be charged for retail energy and monitors service delivery, and licence compliance.

Effective from 1 December 2007, utilising the SCONRRR feeder classifications, NSW electricity distributors were required to reach minimum average reliability performance standards, measured as System Average Interruption Duration Index (SAIDI) and System Average Interruption Frequency Index (SAIFI) by individual feeder type.<sup>21</sup>

These licencing conditions were to be reviewed by the Minister by June 2010 so that any changes or amendments could coincide with the commencement of the 2014-19 regulatory period. To date this has not taken place, however the Australian Energy Market Commission presented its Final Report – NSW Workstream, Review of Distribution Reliability Outcomes and Standards to the New South Wales Government on 31 August 2012 which is currently under review by the Minister.<sup>22</sup>

At present in NSW, the electricity distributors are required to meet and report on the reliability standards on an *average* basis across their network, and also meet and report on reliability performance on an individual feeder basis, which provides a *minimum* level of performance for all customers.

Where an electricity distributor does not meet the individual standard, additional reporting is required, including the cause of exceeding the standard, any action to improve the performance and any operational actions which were identified.<sup>23</sup>

---

<sup>21</sup> Design, Reliability and Performance Licence Conditions for Distribution Network Service Providers  
[http://www.ipart.nsw.gov.au/Home/Industries/Electricity/Licensing/Licence\\_Conditions](http://www.ipart.nsw.gov.au/Home/Industries/Electricity/Licensing/Licence_Conditions)

<sup>22</sup> Australian Energy Market Commission *Final Report – NSW Workstream, Review of Distribution Reliability Outcomes and Standards, 31 August 2012*

<sup>23</sup> Australian Energy Market Commission *Final Report – NSW Workstream, Review of Distribution Reliability Outcomes and Standards, 31 August 2012*



### 2.3.7 AER approach

Since its inception in 2007, the AER has made regulatory determinations for electricity distributors in all National Electricity Market (NEM) jurisdictions.<sup>24</sup> Its most recent determination was for Aurora in Tasmania in April 2012.

Generally, the AER's approach to service standard regulation of electricity distribution businesses has been to apply its STPIS, which has four components, namely reliability of supply, GSLs, quality of supply and customer service.

Only the reliability of supply and GSL components of the STPIS are relevant for present purposes.

The reliability of supply component of the STPIS is based on average performance and implemented through a parameter known as the 's-factor'. If a business exceeds an average performance target for a reliability of supply or customer service indicator it receives a payment. If it falls short of the target, it pays a penalty.

The size of the payment or penalty is determined in advance and known as the incentive rate. Any payment or penalty becomes an adjustment in the electricity distribution tariff, so customers ultimately pay more for superior performance or less for inferior performance, though the magnitude for an individual customer will typically be small.

By contrast to the s-factor, under the GSL component of the STPIS an individual customer who receives service that is below a particular level receives a direct payment.

These two components of the STPIS can be varied in their application by changing their parameters. For the s-factor, the average targets and incentive rates can be changed, while for the GSL component, the GSL payments and GSLs can be changed. In setting the parameters, the regulator needs to remain aware that improved service can only be improved at a cost, so increasing these parameters has implications for network costs and therefore tariffs.

The AER has invariably applied the 's-factor' to feeder categories in all jurisdictions other than Tasmania. It has applied the s-factor using the SCONRRR feeder categories. However, it is not clear that this reflects the AER's preference or that the AER has necessarily considered the question of feeder categorisation in detail.

---

<sup>24</sup> This is all Australian jurisdictions except the Northern Territory and Western Australia.

Under the National Electricity Rules, the AER regulates electricity distribution businesses using a ‘propose-respond’ model. Electricity distributors begin the process by proposing a regulatory framework which the AER has the choice of either accepting or rejecting entirely. The AER cannot modify an electricity distributor’s proposal and can only reject it if it is unreasonable.

In the case of feeder categories, the AER has invariably accepted the electricity distributor’s proposed approach. The only exception is that Aurora proposed that the s-factor scheme should not be applied to its business. The AER did not accept Aurora’s original regulatory proposal, partly for this reason. In its revised proposal, Aurora proposed that the s-factor scheme be applied to the five categories and 101 regions discussed in section 2.3.4 above. The AER accepted Aurora’s revised proposal.

## **2.4 Comparing performance with other jurisdictions**

The purpose of this report is, in part, to assist the Commission in considering whether it is appropriate for the Territory to adopt a different approach to feeder categorisation that is currently used in other jurisdictions.

Any change from the standard feeder type definitions will reduce the extent to which comparisons can be made between the Territory and other jurisdictions.

While this is a reason to consider changes carefully, thought should also be given to the value of those comparisons in the first instance.

Broadly, two types of comparison can be made.

First, with standard feeder categories and reporting, it is relatively simple to compare performance in one jurisdiction with another.

Second, the cost of improving performance could be compared between jurisdictions. For example, the cost of reducing SAIDI by a certain amount could be compared between jurisdictions.

The value of the first comparison is unclear. According to the Energy Supply Association of Australia (esaa) SAIDI in the Territory in 2011 was 405.6 minutes.<sup>25</sup> This is more than any other State or Territory, and more than double that experienced in some States. In 2011 South Australia experienced the lowest SAIDI, with 155.1 minutes, closely followed by Victoria with 186.8 minutes.

In our view this comparison, in itself, is of little value.

---

<sup>25</sup> This excludes Indigenous Essential Services.

The Territory has a particular set of characteristics and a particular network. Its SAIDI performance reflects these things. It would not be reasonable to expect that SAIDI performance in the Territory should be the same as in smaller, more densely populated areas such as Victoria or that portion of South Australia connected to ETSA Utilities' main distribution network. However, there is also no way to determine what the relationship between SAIDI performance in those two places should be.

In any case, at the 'whole of network' level reported by esaa, the ability to make these comparisons is unaffected by feeder category.

Similarly, the value of the second comparison is also unclear. From a regulatory point of view, rather than asking whether a reduction in SAIDI could be achieved more cheaply in another jurisdiction a more important question is to ask whether customers are experiencing optimal levels of service. The answer to this question depends on customers' willingness to pay for service improvements and the cost of supplying those improvements.

To analyse this question, it is important to understand the true cost of improving the service experienced by customers on the particular part of the network to which the customer is connected. The cost of improving service in other jurisdictions is not relevant.

## **2.5 Conclusion – how feeders *should* be categorised**

The purpose of this report is to consider whether the SCONRRR feeder categories are appropriate for the Territory, or, if they are not, how they should be changed.

Before conclusions can be reached about this, the objective of categorising feeders must be defined.

Sections 2.3.1 to 2.3.7 summarise the approaches taken to feeder categorisation in each of the NEM jurisdictions. It is clear that there are two different objectives for feeder categorisation.

It is also clear the same categorisation is not necessarily applied for both objectives.

The two objectives are to apply feeder categories:

1. to enable nationally consistent reporting; and
2. as the basis of regulating service quality, specifically reliability of supply.

Insofar as jurisdictions require their electricity distributors to report reliability performance for national comparison, the basis is the SCONRRR feeder

categories.<sup>26</sup> However some jurisdictions, such as Queensland, have noted the importance of comparing ‘like with like’ and contemplated using different feeder categories to enable this comparison.

Insofar as feeder categorisation is intended as the basis for regulating reliability performance, the approaches vary.

Sections 2.3.1 to 2.3.7 above illustrate that where this issue has been considered closely, the approach, and the conclusion, has been broadly similar.

All jurisdictions that have considered the use of feeder categories as the basis of regulating reliability of supply have concluded that it is equitable for customers in *like* areas to receive a similarly reliable supply of electricity. Similarly, it is equitable for the level of supply reliability to be different in different ‘types’ of area.

The objective of this report is to make recommendations regarding the appropriate feeder categorisation for the draft Code. This aligns closely with the second of the two objectives above. Therefore, for these purposes, our conclusion is that the feeder categories should provide a suitable basis for regulating reliability of supply. In doing this, they should reflect the notion that people in areas that are *alike* should receive like levels of supply reliability.

For the purposes of this report we have assumed that there are two ‘types’ of areas in the Territory supplied by regulated electricity networks, namely urban and rural areas. In effect, we proceed on the basis that it is reasonable for people in either urban or rural areas to expect to receive the same level of supply reliability as other people living in either urban or rural areas, but that it may be unreasonable to expect the same level of reliability in rural areas as in urban areas.

It should be noted that our analysis excludes those parts of the Territory that are not supplied by regulated electricity networks, notably indigenous settlements and Yulara.

---

<sup>26</sup> This requirement has now been discontinued in South Australia.

### 3 Feeder categorisation and the Northern Territory

The Territory occupies a significant part of the centre of the Australian continent. However, much of it is barely populated. Outside Darwin, the Territory's capital, there are a few smaller cities, namely Alice Springs, Katherine, Nhulunbuy and Tennant Creek. Outside these, the population is very sparse.

PWC's regulated electricity networks are in Darwin/Katherine, Alice Springs and Tennant Creek.<sup>27</sup> Between them, these networks comprise of approximately 370 feeders. However, only 162 of these supply customers directly. The remainder are excluded from the analysis in this report.<sup>28</sup>

As required under the Commission's GSL Code, PWC applied the SCONRRR feeder categories to the regulated networks. PWC has suggested that the SCONRRR feeder categories should also be adopted in the draft Code.

The categorisation of feeders in the Darwin area is shown in Figure 1, with different feeder types shown in different colours.

Figure 1 also shows, in pink shading, the various parts of the greater Darwin area that satisfy the Australian Bureau of Statistics' (ABS) definition of an urban area.<sup>29</sup>

There is a large area in the middle of this region that does not meet the ABS's definition of an urban area because it is occupied by a Royal Australian Air Force (RAAF) facility, and is thus sparsely populated.

Further, some parts of Darwin south of the RAAF base are primarily industrial, and do not have sufficient population density to satisfy the ABS's definition of an urban area.

For this report the key issue is to distinguish between urban and rural areas. The industrial part of Darwin and the RAAF base are clearly not rural so they were manually added to the urban area shown in Figure 1 notwithstanding their relatively low population density.

---


<sup>27</sup> The extent of the draft Code, and therefore the analysis in this report, is limited to the networks in these areas.

<sup>28</sup> Some feeders act as backups for other feeders. These feeders do not supply customers in their own right. Other feeders supply bus bars or transformers rather than customers.

<sup>29</sup> The ABS defines an urban area as a population centre of more than 1,000 people with a population density of at least 200 people per square kilometre



Figure 1 **Darwin – feeder categorisation and population density**




Source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)

A clear example of the Commission's concern is seen in the suburbs north of Darwin Airport. Most of that area is supplied by feeders categorised as rural short. However, as the first map shows, this area, which is essentially suburban Darwin, fits entirely within the ABS's definition of 'urban'.

Figure 2, Figure 3 and Figure 4 show the corresponding information for Katherine, Tennant Creek and Alice Springs respectively. They show that a significant proportion of each of these towns is supplied by feeders categorised as rural.




Figure 2 Katherine – feeder categorisation and population density



Source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)



Figure 3 **Tennant Creek – feeder categorisation and population density**




Source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)





Figure 4 Alice Springs – feeder categorisation and population density



Source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)

Two aspects of the definition of urban should be noted.

First, there is an area on the western edge of Darwin airport, between Ludmilla and Coconut Grove, which is too sparsely populated to meet the ABS definition of urban, though we note that the definition also extends to include areas surrounded by areas with sufficiently dense population. Notwithstanding that this extension may incorporate this area, it is not marked as urban in the maps in this report. However, this makes no difference to the feeder categorisation.

Second, there is an area south of Alice Springs and disconnected from the main township that is sufficiently densely populated to meet the ABS's definition of urban. This is Statistical Area 1 number 7105202. It has an area of 0.86 square kilometres and a population of 561, so it meets the ABS's definition. This said, there does not appear to be a large cluster of homes in this region. In the absence of specific information to the contrary we have trusted the 2011 ABS census data to be correct.

### 3.1 Whether PWC has applied the feeder categorisation correctly

ACIL Tasman applied the SCONRRR feeder categories to PWC's networks based on data supplied by PWC. In some cases we did not have sufficient data to compute the categorisation, though we understand this only affected feeders that do not supply customers. In all other cases, our analysis confirmed PWC's application of the SCONRRR categories. Therefore, we conclude that PWC's application of the categories was correct.

In conducting this check we attempted to reproduce the feeder length data that PWC provided from the GIS data for a sample of feeders in Tennant Creek.

We were not able to replicate the feeder lengths. However, this appears to reflect the fact that feeders may comprise several smaller elements, which our approach to estimating feeder length would tend to double count.

We cannot confirm PWC's data regarding the length of its feeders, but nor can we conclude that it is not correct.

### 3.2 Alternative approach to feeder categorisation

Having verified PWC's application of the SCONRRR feeder categories, the next tasks for which ACIL Tasman was engaged were to:

- identify alternatives to the SCONRRR feeder categories that would best serve the objectives of the Code while allowing PWC to report consistently with its peers and minimising reporting costs;
- determine whether it is appropriate for the Commission to use the SCONRRR feeder categories as the basis for setting targets for reliability of supply and, if not, what alternative methods may be more appropriate (including, but not limited to, amendments to the SCONRRR feeder definition categories).

These two items are similar. They are addressed jointly in this section.

The Commission's concern arises from the fact that a number of feeders in urban areas are categorised as rural.<sup>30</sup> We are not aware of any concerns regarding the feeders defined as CBD. Therefore, our analysis was focussed on the distinction between urban and rural feeders.

---

<sup>30</sup> The distinction between short and long rural feeders is based on the length of the feeder. It is not relevant for present purposes.

We identified three alternative approaches that could be used to categorise feeders in the Territory. These were:

1. apply the same approach as the SCONRRR definitions, but change the threshold MVA/km value to better distinguish urban and rural feeders
2. categorise feeders as ‘radial’ or ‘meshed’
3. set performance targets for specific (geographic) locations.

These three options are discussed in more detail in sections 3.2.1 to 3.2.3. Our recommended approach, which is a hybrid of these three options, is discussed in section 3.3. That approach is applied to the regulated networks in chapter 5.

### 3.2.1 Re-align feeder categories by altering threshold value

The two feeder categories that are central to the Commission’s concern are ‘rural (short and long)’ and ‘urban’. The difference between feeders in these two categories, as defined, is that urban feeders serve load above a threshold of 0.3 MVA per km while rural feeders (long or short) serve less load.<sup>31</sup>

Conceptually, the SCONRRR feeder categories could be altered simply by changing the threshold value. All else being equal if the threshold was lowered the number of ‘rural’ feeders would reduce and the number of ‘urban’ feeders would increase.

We understand that the threshold value in SCONRRR’s definition was selected by taking frequency scatter plots of the maximum demand observed on feeders in Victoria. The threshold value was somewhat arbitrary and inherently reflects Victorian conditions from the late 1990s.

Given the structure of the definitions, the feeder categories could be redefined simply by changing the threshold value. The advantage of this approach is that it may only require a small change from the existing SCONRRR definitions.

There are three disadvantages.

First, categorising feeders by reference to the load they serve is only as accurate as the link between the load served and the type of area the feeder serves. For example, a long feeder that serves a very large load would have the same average MVA/km as a shorter feeder with a smaller load, though the areas they serve may not be alike.

In other words, there may be little or no relationship between the load on a feeder (per km) and the type of area it supplies. In practice we expect that there is a high correlation between the load on a feeder and the type of area it

---

<sup>31</sup> Rural feeders are then categorised by feeder length using a threshold of 200 km.

supplies, so this may not be a large problem and that it could be addressed by including an element of discretion to override the automatic categorisation of certain feeders.

Second, the approach is inherently arbitrary. Without an additional source of information it would be impossible to know if the ‘right’ threshold value has been chosen. A method for overcoming this disadvantage is discussed in section 3.3.

Third, as with any change from the standard SCONRRR definitions, changing the threshold would reduce the ability to compare with other jurisdictions.

However, we anticipate that systems could be established to ensure that, if desired, reporting could be based on the standard SCONRRR definition even if the threshold value was changed for the purpose of setting reliability targets.

### **3.2.2 Categorise feeders as radial or meshed**

Rather than categorising feeders according to the SCONRRR definitions, it would be possible to categorise them simply as ‘radial’ or ‘meshed’. This approach is applied under the original Code.

The advantage of this approach is that it is more closely related to the nature of the network.

The disadvantage is that there does not appear to be a universally accepted definition of the terms ‘radial’ and ‘meshed’. Our understanding of these two terms is that a radial network is characterised by few, if any, redundant elements. By contrast, a meshed network is characterised by multiple redundant elements.

We note that the number of redundant elements is a question of degree and this definition may not be sufficiently precise for regulatory purposes.

Contrary to our understanding of the terms, we understand that under the original Code PWC has interpreted these terms such that ‘radial’ feeders were all feeders operating at 22kV and meshed feeders were all feeders operating at 11kV.

A modification of this approach would be to use these two voltage levels as the basis of feeder categorisation. PWC has traditionally used 22kV feeders in rural areas and 11kV feeders in urban areas.

However, we also understand that PWC now has plans to increase the use of 22kV feeders in urban areas. Therefore, while continuing to rely on this definition of feeder types may address the Commission’s concern in the short term, the issue is likely to return in future.

Another disadvantage with this approach is that, as with any departure from the SCONRRR definitions, it would not allow comparison with other jurisdictions. Unlike an approach based on a different threshold value, we anticipate that producing reports based on feeder voltages would require a more substantial redesign of PWC's information systems, though the necessary systems may also be in place given that this approach has been used historically.

### **3.2.3 Set performance targets for identified geographic locations**

The third approach we considered to feeder categorisation for the purpose of setting reliability of supply targets was to base them on pre-determined geographic zones.

This is similar to the approach ESCOSA took with its seven regional zones (see section 2.3.3). It is also similar to the approach taken in Tasmania where its 101 regions were identified based on 'likeness' and then assigned to a service category (see section 2.3.4).

This approach has the advantage of allowing a great deal of flexibility, as the Commission could simply apply standards on a 'place by place' basis. It has the advantage that targets can be set to reflect either the actual performance in an area or a reasonable improvement from that level.

However, this approach has two disadvantages.

First, as with the approach discussed in section 3.2.2, the change from the SCONRRR definitions represented by this approach are likely to be such that it would not provide a meaningful comparison with other jurisdictions.

Second, as with the voltage based option discussed in section 3.2.2, producing the necessary reports may require a more substantial redesign of PWC's information systems than a simple change to the threshold value.

## **3.3 Recommended approach – a hybrid**

Our recommended approach to categorising feeders in the Territory is a hybrid of options 1 and 3 above.

We recommend that the Commission adopt the principle that customers in like areas can reasonably expect to receive similar levels of reliability performance to one another and set its feeder definitions and GSL scheme accordingly.

To minimise the extent of the change from the SCONRRR definitions, and thus to minimise the change (and cost) required of PWC and to preserve the ability to report on a nationally consistent basis, we recommend that the

Commission defines feeder categories using the SCONRRR definitions and reduce the MVA/km but reduce threshold value used to define urban feeders.

To identify the appropriate threshold value, the Commission will need to identify which parts of the Territory are alike and different. We recommend dividing the Territory into three area types:

- Urban areas – areas that satisfy the ABS’s definition of an urban area or are otherwise identified as being urban (industrial) areas
- Rural areas – areas that are supplied by the regulated networks but do not meet the definition of urban
- Unregulated areas – areas that are not supplied by the regulated networks

Having done this, we recommend that the Commission identify the types of areas that each customer feeder supplies and allocate feeders accordingly.

This will provide a ‘target’ categorisation for each feeder, but not necessarily the final definition.

We recommend that the Commission identifies the threshold value that provides the best match with the ‘target’ categorisation and adopt this as the threshold value for its feeder categories.

We have applied our recommended approach to PWC’s network in chapter 5

## 4 The available data

The analysis in chapter 5 of this report was based on data provided to ACIL Tasman by PWC, through the Commission. That data came in two tranches:

1. feeder data - feeder load, length and connections (customers) data and PWC's application of the SCONRRR feeder categories provided for 372 feeders
2. geographic information system (GIS) data - were provided for 237 items, though these appear to be only 162 unique feeders.<sup>32</sup>

A brief overview of the data PWC supplied is provided below. There are some aspects of the data that require explanation or in relation to which we made certain assumptions. Those aspects are outlined in this section.

We understand that the two tranches of data were drawn from different systems. Data drawn from PWC's Feeder Information System (FIS) were only available for customer feeders, that is, feeders that were included in PWC's calculation of SAIDI and SAIFI.

Generally the data were straightforward and, in our view, appropriate for the analysis required.

The feeder data were provided in an Excel spreadsheet. The columns included in the spreadsheet, along with our understanding of their contents, were:

1. Two Feeder Identifiers:
  - a) First, an alphanumeric 'name' for each feeder which appears to provide certain descriptive information, such as voltage and location, e.g. 11AK02 Knuckey St; and
  - b) Second, a shorter alphanumeric 'name' for each feeder with no descriptive information, e.g. NR0006.
2. Feeder final – an alphanumeric 'name' for each feeder formatted similarly to the longer form of feeder ID and usually the same as FEEDER\_ID though for some feeders it was blank. We understand that feeder final was drawn from the FIS and that the purpose of this column was to link data from the two systems together. It was blank for feeders not modelled in FIS.

---

<sup>32</sup> There were two additional feeders for which GIS data were provided without identifiers. These feeders were disregarded.

3. Feeder length final – the length of each feeder (in km) based on FIS using data for March 2012. This was 0.0 for (non-customer) feeders which have not been modelled in FIS.
4. Service count – the number of customers connected to each feeder.
5. Meshed/Radial – as discussed in section 3.2.2, we understand that the meshed and radial classification was determined by voltage - 11kV = Meshed, 22kV = Radial.
6. Customer Feeder – certain feeder categories were defined as ‘non-customer’ feeders, for example feeders that supply capacitor banks, bus bars or transformers.
7. Feeder MVA – the maximum load observed on each feeder in 2010/11.
8. Feeder MVA/km – the quotient of feeder MVA and feeder length.
9. ESAA Category – the feeder category determined in accordance with the SCONRRR definitions.
10. Region – the region where the feeder is located (not used).

Our preliminary analysis of the data revealed a small number of inconsistencies which were discussed with PWC. Some changes were made to the original dataset as a result. Most were immaterial.

There is a slight discrepancy in the timing of the data we were provided. Specifically, feeder lengths were calculated in March 2012 while loads were taken from 2010/11. Conceptually we do not see this as a problem.

A related issue was that load data were not provided for all feeders. Of the 162 feeders for which GIS data were provided a complete set of load and length data were provided for only 115. There were various reasons for the absence of data for the remaining feeders. Some feeders were not in use when load data were collected. Other feeders were in use, but PWC was not able to provide SCADA data.

The 47 feeders for which a complete set of data was not provided were not able to be incorporated in the analysis. The practical implication was that we were unable to compute the impact of changing the threshold MVA/km value on these feeders. This applied to 39 feeders because some were categorised (by PWC) as CBD (which does not rely on length and load data) and others were assigned a target definition that corresponded with the SCONRRR definition.

A list of the 115 feeders for which a full set of feeder and GIS data is provided in Table 1.



Table 1 **Feeders with full set of data**

#	Feeder
1	11AK03 AUSTIN LANE
2	11BE01 LEANYER
3	11BE03 TDZ
4	11BE04 MCMILLANS
5	11BE06 KARAMA 1
6	11BE07 NAVY
7	11BE09 JAIL
8	11BE10 KARAMA 2
9	11BE13 KORMILDA
10	11BE14 ROBINSON
11	11BE16 ANULA
12	11BE18 PORT
13	11CA00 NIGHTCLIFF 1
14	11CA03 BRADSHAW
15	11CA04 NTU
16	11CA06 FAC- LYONS
17	11CA07 JINGILI
18	11CA10 MILLNER
19	11CA12 MARRARA
20	11CA13 WANGURI
21	11CA15 HOSPITAL
22	11CA16 NAKARA
23	11CA17 CAS SQUARE
24	11CA19 CAS VILLAGE
25	11CA23 MOIL
26	11CA24 CAZSS BUSTIE 3/4
27	11CA25 BRINKIN
28	11CZ02 WEST BENNETT 1
29	11CZ03 AUSTIN KNUCKEY 1
30	11CZ05 WOODS ST 1
31	11CZ06 MOTT ST 1
32	11CZ07 STUART PARK
33	11CZ09 AUSTIN KNUCKEY 2
34	11CZ10 MITCHELL ST 1
35	11CZ12 MOTT STREET 2
36	11CZ13 WEST BENNETT 2
37	11CZ14 GARDENS
38	11CZ16 WOODS ST 2
39	11CZ17 MITCHELL ST 2
40	11CZ19 CITY VALLEY

#	Feeder
41	11CZ20 DINAH BEACH
42	11FB09 WATERFRONT
43	11LG06 BRADSHAW
44	11LG07 ARALUEN
45	11LG13 ELDER
46	11LG15 LARAPINTA
47	11LG16 BRAITLING
48	11ML09 DALY
49	11PA02 WALER
50	11PA03 PALM SHOPS
51	11PA04 BAKEWELL
52	11PA07 GRAY
53	11PA08 GUNN
54	11PA09 TF T1
55	11PA10 DRIVER
56	11PA11 FARRAR
57	11PA15 MOULDEN
58	11PA17 THORNGATE
59	11PA18 WOODROFFE
60	11PA19 DURACK
61	11PA21 YARRAWONGA
62	11PA22 PALM CIVIC
63	11PA23 GEORGINA
64	11RG01 GAP
65	11RG02 GOLF COURSE
66	11RG06 SADADEEN
67	11RG07 HOSPITAL
68	11RG08 CBD
69	11RG19 NTHSTUHWY
70	11RG20 WILLS
71	11RG21 GILLEN
72	11SN01 FANNIE BAY
73	11SN02 BAGOT
74	11SN05 MARANGA
75	11SN07 BAYVIEW
76	11SN10 GOYDER
77	11SN13 BISHOP
78	11SN14 COONAWARRA
79	11SN16 PARAP
80	11SN17 RAAF



ACIL Tasman

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

#	Feeder
81	11SN19 LUDMILLA
82	11WB08 WHARF PRECINCT
83	11WS03 DASHWOOD
84	11WS08 CULLEN
85	11WS11 KITCHENER
86	22BR102 BOREFIELDS
87	22HD402 LAMBELLS
88	22HD403 MIDDLE POINT
89	22KP03 TINDAL 2
90	22KP04 KATH EAST
91	22KP06 PINE CREEK
92	22KP07 MATARANKA
93	22KP11 OPS TIE
94	22KP12 FLORINA
95	22KP14 GORGE
96	22KP15 TINDAL 1
97	22MA02 BATCHELOR
98	22MA03 ADELAIDE RIVER

#	Feeder
99	22MA07 ACACIA
100	22MM05 HERBERT
101	22MM06 STRANGWAYS
102	22MM07 NOONAMAH
103	22MM09 MCMINNS PUMPS
104	22MM10 VIRGINIA
105	22MM11 DARWIN RIVER
106	22MM13 DUNDEE
107	22MR103 MT BUNDY
108	22PA101 HOWARD SPRINGS
109	22PC308 PCK TOWNSHIP
110	22RG04 BREWER 2
111	22RG09 FARMS
112	22RG13 BREWER 1
113	22TC202 FEEDER 2
114	22TC302 FEEDER 3
115	22TC602 FEEDER 6

## 5 Application of feeder categories

As discussed in section 3.3, we recommend that the Commission take a three step approach to categorising feeders as follows:

1. Identify areas in the Territory using ‘urban’, ‘rural’ and ‘unregulated’ zones.
2. Determine which of these two zones each feeder supplies.<sup>33</sup>
3. Identify the threshold value that provides the best correspondence between the feeder categorisation developed in step 2 and SCONRRR categorisation based on that threshold.

These three steps are applied in the following sections.

### 5.1 Categorise areas in the Territory

As discussed in section 3, the ABS defines an urban centre as one which has:

- a population of more than 1,000 persons.
- a population density of at least 200 persons per square km.

Figure 1 to Figure 4 above show the parts of the Territory that we consider to be urban areas. The areas marked in those figures either satisfy the ABS’s definition of urban, based on population density, or have been identified as being industrial in nature, and are thus clearly not rural. The remainder of the area connected to the regulated networks is defined as rural.

### 5.2 Determine which zones each feeder supplies

The next step was to identify the feeders that supply ‘urban’ areas and those which supply rural areas. For this purpose PWC provided GIS data regarding the location of each of its (customer) feeders.

Theoretically, this analysis should be based on the location of customers supplied by each feeder. However, this is not available. That is, PWC does not have detailed data regarding the location of each of its customers.<sup>34</sup>

In the absence of data concerning the location of customers themselves we assumed that feeders supply the area where they are located. In most cases this was acceptable. However, in a small number of cases we noted that some

---

<sup>33</sup> By definition the regulated networks do not supply customers in unregulated areas so the feeder with which we are concerned can only be in one of the other two zones.

<sup>34</sup> It is not surprising that a distribution network business does not have this level of data.

feeders passed through urban areas and then extended for a significant distance into rural areas. These feeders are marked here as ‘mixed’.<sup>35</sup>

Therefore, each feeder was assigned a target categorisation as shown in Table 2. Note that all 162 feeders are listed in Table 2, though the next section, relating to selecting the threshold value, is limited to the 115 feeders for which a full set of data was available.

---

<sup>35</sup> We have no way of knowing whether those feeders supply customers in urban areas ‘on their way’ to rural areas, though it seems likely.

Table 2 **Target feeder categorisations**

#	Feeder	target
1	11AK03 AUSTIN LANE	CBD
2	11BE01 LEANYER	Urban
3	11BE03 TDZ	Urban
4	11BE04 MCMILLANS	Urban
5	11BE06 KARAMA 1	Urban
6	11BE07 NAVY	Urban
7	11BE08 BEZSS BUSTIE 1/2	Urban
8	11BE09 JAIL	Urban
9	11BE10 KARAMA 2	Urban
10	11BE11 BEZSS CAP BANK	Urban
11	11BE13 KORMILDA	Urban
12	11BE14 ROBINSON	Urban
13	11BE16 ANULA	Urban
14	11BE17 BEZSS BUSTIE 2/3	Urban
15	11BE18 PORT	Urban
16	11BE21 BEZSS BUSTIE 3/4	Urban
17	11CA00 NIGHTCLIFF 1	Urban
18	11CA01 CA CAP NO 1	Urban
19	11CA01 CAZSS CAP BANK No 1	Urban
20	11CA03 BRADSHAW	Urban
21	11CA04 NTU	Urban
22	11CA06 FAC- LYONS	Urban
23	11CA07 JINGILI	Urban
24	11CA08 NORTH LAKES	Urban
25	11CA09 CAZSS BUSTIE 1/2	Urban
26	11CA10 MILLNER	Urban
27	11CA11 CAZSS CAP BANK No 2	Urban
28	11CA12 MARRARA	Urban
29	11CA13 WANGURI	Mixed
30	11CA15 HOSPITAL	Urban
31	11CA16 NAKARA	Urban
32	11CA17 CAS SQUARE	Urban
33	11CA18 CAZSS BUSTIE 2/3	Urban
34	11CA19 CAS VILLAGE	Urban

#	Feeder	target
35	11CA21 NIGHTCLIFF 2	Urban
36	11CA23 MOIL	Urban
37	11CA24 CAZSS BUSTIE 3/4	Urban
38	11CA25 BRINKIN	Urban
39	11CAZSS BUS 1	Urban
40	11CAZSS BUS 3	Urban
41	11CP4306 WAGAIT	Rural Short
42	11CP4307 BELYUEN	Rural Short
43	11CZ01 CZZSS CAP BANK No 2	CBD
44	11CZ02 WEST BENNETT 1	CBD
45	11CZ03 AUSTIN KNUCKEY 1	CBD
46	11CZ05 WOODS ST 1	CBD
47	11CZ06 MOTT ST 1	CBD
48	11CZ07 STUART PARK	Urban
49	11CZ08 CZZSS BUSTIE 1/2	CBD
50	11CZ09 AUSTIN KNUCKEY 2	CBD
51	11CZ10 MITCHELL ST 1	CBD
52	11CZ12 MOTT STREET 2	CBD
53	11CZ13 WEST BENNETT 2	CBD
54	11CZ14 GARDENS	Urban
55	11CZ16 WOODS ST 2	CBD
56	11CZ17 MITCHELL ST 2	CBD
57	11CZ19 CITY VALLEY	Urban
58	11CZ20 DINAH BEACH	Urban
59	11CZ21 CZZSS CAP BANK No 1	Urban
60	11CZZSS BUS 1	CBD
61	11CZZSS BUS 2	CBD
62	11CZZSS BUS 3	CBD
63	11FB09 WATERFRONT	Urban
64	11LG06 BRADSHAW	Urban
65	11LG07 ARALUEN	Urban



ACIL Tasman

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

#	Feeder	target
66	11LG13 ELDER	Urban
67	11LG15 LARAPINTA	Urban
68	11LG16 BRAITLING	Urban
69	11ML09 DALY	CBD
70	11PA01 PAZSS BUSTIE 1/2	Urban
71	11PA02 WALER	Urban
72	11PA03 PALM SHOPS	Urban
73	11PA04 BAKEWELL	Urban
74	11PA06 PAZSS CAP BANK No 2	Urban
75	11PA07 GRAY	Urban
76	11PA08 GUNN	Urban
77	11PA09 TF T1	Urban
78	11PA10 DRIVER	Mixed
79	11PA11 FARRAR	Urban
80	11PA12 PAZSS AUX TF 1	Urban
81	11PA13 PAZSS BUSTIE 2/3	Urban
82	11PA14 PAZSS AUX TF 2	Urban
83	11PA15 MOULDEN	Urban
84	11PA16 PAZSS CAP BANK No 1	Urban
85	11PA17 THORNGATE	Urban
86	11PA18 WOODROFFE	Urban
87	11PA19 DURACK	Urban
88	11PA21 YARRAWONGA	Urban
89	11PA22 PALM CIVIC	Urban
90	11PA23 GEORGINA	Urban
91	11RG01 GAP	Urban
92	11RG02 GOLF COURSE	Urban
93	11RG06 SADADEEN	Urban
94	11RG07 HOSPITAL	Urban
95	11RG08 CBD	Urban
96	11RG19 NTHSTUHWY	Urban
97	11RG20 WILLS	Urban
98	11RG21 GILLEN	Urban
99	11SN01 FANNIE BAY	Urban
100	11SN02 BAGOT	Urban
101	11SN04 SNZSS CAP BANK No 2	Urban

#	Feeder	target
102	11SN05 MARANGA	Urban
103	11SN07 BAYVIEW	Urban
104	11SN10 GOYDER	Urban
105	11SN13 BISHOP	Urban
106	11SN14 COONAWARRA	Urban
107	11SN16 PARAP	Urban
108	11SN17 RAAF	Urban
109	11SN19 LUDMILLA	Urban
110	11SN20 SNZSS CAP BANK No 1	Urban
111	11WB01 PARLIAMENT	CBD
112	11WB08 WHARF PRECINCT	Urban
113	11WS03 DASHWOOD	CBD
114	11WS08 CULLEN	Urban
115	11WS11 KITCHENER	CBD
116	11YU04 No.1 FEEDER	Rural Short
117	11YU10 No.2 FEEDER	Rural Short
118	11YU17 No.3 FEEDER	Rural Short
119	22BR102 BOREFIELDS	Rural Short
120	22HD402 LAMBELLS	Rural Short
121	22HD403 MIDDLE POINT	Rural Short
122	22KP01 AUX TF 1	Rural Short
123	22KP03 TINDAL 2	Rural Short
124	22KP04 KATH EAST	Urban
125	22KP06 PINE CREEK	Rural Short
126	22KP07 MATARANKA	Rural Long
127	22KP11 OPS TIE	Rural Short
128	22KP12 FLORINA	Rural Short
129	22KP14 GORGE	Rural Short
130	22KP15 TINDAL 1	Rural Short
131	22KP17 AUX TF 2	Rural Short



ACIL Tasman

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

#	Feeder	target
132	22KP19 KATHERINE TOWN	Urban
133	22MA02 BATCHELOR	Rural Short
134	22MA03 ADELAIDE RIVER	Rural Short
135	22MA04 NTP	Rural Short
136	22MA05 LAKE BENNETT	Rural Short
137	22MA07 ACACIA	Rural Short
138	22MM02 MMZSS CAP BANK	Rural Short
139	22MM05 HERBERT	Rural Short
140	22MM06 STRANGWAYS	Rural Short
141	22MM07 NOONAMAH	Rural Short
142	22MM09 MCMINNS PUMPS	Rural Short
143	22MM10 VIRGINIA	Rural Short
144	22MM11 DARWIN RIVER	Rural Short
145	22MM13 DUNDEE	Rural Short
146	22MR103 MT BUNDY	Rural


#	Feeder	target
		Short
147	22MR303 TOMS GULLY	Rural Short
148	22PA101 HOWARD SPRINGS	Rural Short
149	22PC306 MOLINE	Rural Short
150	22PC308 PCK TOWNSHIP	Rural Short
151	22RG04 BREWER 2	Rural Short
152	22RG09 FARMS	Mixed
153	22RG13 BREWER 1	Mixed
154	22TC202 FEEDER 2	Rural Short
155	22TC302 FEEDER 3	Urban
156	22TC402 FEEDER 4	Urban
157	22TC502 FEEDER 5	Mixed
158	22TC602 FEEDER 6	Rural Long
159	CZ-CP	Rural Short
160	LOVEGROVE EXPRESS FDR 1	Urban
161	LOVEGROVE EXPRESS FDR 2	Mixed
162	PINE CK - COSMO HOWLEY	Rural Short

### 5.3 Select the threshold value

The third step in our approach was to select a threshold value that, when used in the SCONRRR definition, would provide the best possible match with the target categorisation.

Feeder categorisation for PWC's customer feeders was re-calculated with thresholds ranging from 0.05 MVA/km to 1.0 MVA/km. The resulting categories were compared with the standard SCONRRR categorisations of PWC's customer feeders. The degree to which the two definitions matched is shown in Figure 5.<sup>36</sup>

Figure 5 'Fit' between categorisations with different thresholds



Source: ACIL Tasman analysis

As Figure 5 shows, the best match, approximately 95 per cent of the 117 feeders for which the necessary data were provided,<sup>37</sup> is achieved with a threshold of 0.12 MVA/km. That is, if the SCONRRR definition is modified so that the distinction between rural and urban feeders is drawn at a load of 0.12 MVA/km, rather than 0.3 MVA/km, 95 per cent of PWC's feeders would be categorised in accordance with our view based on the feeder locations.

With the standard SCONRRR threshold the match is 75 per cent. The lower threshold provides a significantly better match between the two definitions. In fact, any value less than 0.3 MVA/km provides a better match than the SCONRRR threshold of 0.3 MVA/km.

<sup>36</sup> Percentages are shown based on 117 feeders. Feeders for which a full set of data was not provided are excluded unless they were categorised as CBD. Mixed feeders are excluded.

<sup>37</sup> See footnote 36.



This process identified a hierarchy of feeder ‘groups’ as follows. The details of which feeders fall into which group are shown in the following tables:

1. 87 feeders for which the SCONRRR definition corresponds with our ‘target’ definition and thus required no further analysis (Table 3).
2. 75 feeders for which the SCONRRR definition does not correspond with our target definition comprising:
  - a) 30 feeders which would be re-categorised from rural to urban based on a threshold value of 0.12 MVA/km (Table 4)
  - b) 45 feeders for which we cannot make a firm recommendation, comprising:
    - i 6 feeders defined as rural using the SCONRRR definition that cross from urban to rural areas (mixed feeders) (Table 5); and
    - ii 39 feeders for which we received incomplete data and thus cannot compute the impact of a 0.12 MVA/km threshold (Table 6).
  - c) 6 feeders which would be ‘mis-matched’ with our target categorisation at a threshold of 0.12 MVA/km.<sup>38</sup>

---

<sup>38</sup> Three of these feeders are among the 30 that would be re-categorised at the identified threshold as well as the 87 whose initial and target categorisations align. Therefore the numbers here do not add to 162 due to double counting. To reconcile to 162, sum:

- 84 feeders with ‘matching’ definitions that are not also identified as mismatches
- 6 feeders with mismatched definitions (three that are changed incorrectly and three that are not changed)
- 27 feeders whose categorisation is recommended to change that are not also identified as mismatches
- 6 mixed feeders and
- 39 feeders with incomplete data.

Table 3 **PWC definition matched target definition – no further analysis**

#	Feeder
1	11AK03 AUSTIN LANE
2	11BE07 NAVY
3	11BE10 KARAMA 2
4	11BE14 ROBINSON
5	11CA00 NIGHTCLIFF 1
6	11CA04 NTU
7	11CA12 MARRARA
8	11CA15 HOSPITAL
9	11CA17 CAS SQUARE
10	11CA24 CAZSS BUSTIE 3/4
11	11CA25 BRINKIN
12	11CZ01 CZZSS CAP BANK No 2
13	11CZ02 WEST BENNETT 1
14	11CZ03 AUSTIN KNUCKEY 1
15	11CZ05 WOODS ST 1
16	11CZ06 MOTT ST 1
17	11CZ07 STUART PARK
18	11CZ08 CZZSS BUSTIE 1/2
19	11CZ09 AUSTIN KNUCKEY 2
20	11CZ10 MITCHELL ST 1
21	11CZ12 MOTT STREET 2
22	11CZ13 WEST BENNETT 2
23	11CZ14 GARDENS
24	11CZ16 WOODS ST 2
25	11CZ17 MITCHELL ST 2
26	11CZ19 CITY VALLEY
27	11CZZSS BUS 1
28	11CZZSS BUS 2
29	11CZZSS BUS 3
30	11FB09 WATERFRONT
31	11LG06 BRADSHAW
32	11LG07 ARALUEN
33	11LG13 ELDER
34	11LG16 BRAITLING
35	11ML09 DALY
36	11PA02 WALER
37	11PA03 PALM SHOPS
38	11PA07 GRAY
39	11PA08 GUNN
40	11PA09 TF T1

#	Feeder
41	11PA18 WOODROFFE
42	11PA19 DURACK
43	11PA22 PALM CIVIC
44	11RG01 GAP
45	11RG02 GOLF COURSE
46	11RG07 HOSPITAL
47	11RG08 CBD
48	11RG20 WILLS
49	11SN07 BAYVIEW
50	11SN10 GOYDER
51	11SN13 BISHOP
52	11SN14 COONAWARRA
53	11SN16 PARAP
54	11SN17 RAAF
55	11SN19 LUDMILLA
56	11WB01 PARLIAMENT
57	11WB08 WHARF PRECINCT
58	11WS03 DASHWOOD
59	11WS08 CULLEN
60	11WS11 KITCHENER
61	22BR102 BOREFIELDS
62	22HD402 LAMBELLS
63	22HD403 MIDDLE POINT
64	22KP03 TINDAL 2
65	22KP06 PINE CREEK
66	22KP07 MATARANKA
67	22KP11 OPS TIE
68	22KP12 FLORINA
69	22KP14 GORGE
70	22KP15 TINDAL 1
71	22MA02 BATCHELOR
72	22MA03 ADELAIDE RIVER
73	22MA07 ACACIA
74	22MM05 HERBERT
75	22MM06 STRANGWAYS
76	22MM07 NOONAMAH
77	22MM09 MCMINNS PUMPS
78	22MM10 VIRGINIA
79	22MM11 DARWIN RIVER
80	22MM13 DUNDEE

## Independent review of distribution network feeder category definitions

#	Feeder
81	22MR103 MT BUNDY
82	22PA101 HOWARD SPRINGS
83	22PC308 PCK TOWNSHIP
84	22RG04 BREWER 2

Data source: ACIL Tasman analysis

#	Feeder
85	22TC202 FEEDER 2
86	22TC302 FEEDER 3
87	22TC602 FEEDER 6

Table 4 **Feeders recommended to be re-categorised as urban**

#	Feeder
1	11BE01 LEANYER
2	11BE03 TDZ
3	11BE06 KARAMA 1
4	11BE09 JAIL
5	11BE13 KORMILDA
6	11BE16 ANULA
7	11CA03 BRADSHAW
8	11CA06 FAC- LYONS
9	11CA07 JINGILI
10	11CA10 MILLNER
11	11CA16 NAKARA
12	11CA19 CAS VILLAGE
13	11CA23 MOIL
14	11CZ20 DINAH BEACH
15	11LG15 LARAPINTA

#	Feeder
16	11PA04 BAKEWELL
17	11PA11 FARRAR
18	11PA15 MOULDEN
19	11PA17 THORNGATE
20	11PA21 YARRAWONGA
21	11PA23 GEORGINA
22	11RG06 SADADEEN
23	11RG19 NTHSTUHWY
24	11RG21 GILLEN
25	11SN01 FANNIE BAY
26	11SN05 MARANGA
27	22BR102 BOREFIELDS
28	22KP03 TINDAL 2
29	22KP04 KATH EAST
30	22MM09 MCMINNS PUMPS

<sup>a</sup> the McMinns pumps feeder may require special consideration, see below.

Data source: ACIL Tasman analysis

Table 5 **Mixed feeders**

#	Feeder
1	11CA13 WANGURI
2	11PA10 DRIVER
3	22RG09 FARMS
4	22RG13 BREWER 1
5	22TC502 FEEDER 5
6	LOVEGROVE EXPRESS FDR 2

Data source: ACIL Tasman analysis

Table 6 **Feeders with incomplete data**

#	Feeder	#	Feeder
1	11BE08 BEZSS BUSTIE 1/2	21	11PA14 PAZSS AUX TF 2
2	11BE11 BEZSS CAP BANK	22	11PA16 PAZSS CAP BANK No 1
3	11BE17 BEZSS BUSTIE 2/3	23	11SN04 SNZSS CAP BANK No 2
4	11BE21 BEZSS BUSTIE 3/4	24	11SN20 SNZSS CAP BANK No 1
5	11CA01 CA CAP NO 1	25	11YU04 No.1 FEEDER
6	11CA01 CAZSS CAP BANK No 1	26	11YU10 No.2 FEEDER
7	11CA08 NORTH LAKES	27	11YU17 No.3 FEEDER
8	11CA09 CAZSS BUSTIE 1/2	28	22KP01 AUX TF 1
9	11CA11 CAZSS CAP BANK No 2	29	22KP17 AUX TF 2
10	11CA18 CAZSS BUSTIE 2/3	30	22KP19 KATHERINE TOWN
11	11CA21 NIGHTCLIFF 2	31	22MA04 NTP
12	11CAZSS BUS 1	32	22MA05 LAKE BENNETT
13	11CAZSS BUS 3	33	22MM02 MMZSS CAP BANK
14	11CP4306 WAGAIT	34	22MR303 TOMS GULLY
15	11CP4307 BELYUEN	35	22PC306 MOLINE
16	11CZ21 CZZSS CAP BANK No 1	36	22TC402 FEEDER 4
17	11PA01 PAZSS BUSTIE 1/2	37	CZ-CP
18	11PA06 PAZSS CAP BANK No 2	38	LOVEGROVE EXPRESS FDR 1
19	11PA12 PAZSS AUX TF 1	39	PINE CK - COSMO HOWLEY
20	11PA13 PAZSS BUSTIE 2/3		

Data source: ACIL Tasman analysis

The 0.12MVA/km threshold does not provide a perfect match with our target categorisations. At this threshold the six feeders listed in Table 7 would be mis-categorised by reference to their target categorisation.

Table 7 **Mismatched feeders**

Feeder	Initial categorisation	Target categorisation	MVA/km	Recommended categorisation at 0.12 MVA/km
11BE04 MCMILLANS	Rural Short	Urban	0.07	Rural Short
11BE18 PORT	Rural Short	Urban	0.07	Rural Short
11SN02 BAGOT	Rural Short	Urban	0.11	Rural Short
22BR102 BOREFIELDS	Rural Short	Rural Short	0.23	Urban
22KP03 TINDAL 2	Rural Short	Rural Short	0.13	Urban
22MM09 MCMINNS PUMPS	Rural Short	Rural Short	0.26	Urban

Note: Three of the feeders in this table are also in Table 3, so the total number of feeders does not add correctly.

For three of these feeders, the load is not high enough to ‘cross’ even the lower threshold. In other words, while our recommended approach resolves some of the Commission’s concerns, it does not resolve all of them.

For the remaining three mismatched feeders, adopting a threshold of 0.12 causes them to be defined as urban even though they are not in urban areas.

That is, the change in threshold creates the reverse issue to that identified by the Commission in the first place.

This is a counter-intuitive result that should ideally be avoided. However, we understand that none of these feeders could be described as a typical rural feeder. Rather, we understand that one supplies a water pumping station owned by PWC and no other services, which makes it an unusual feeder that is not truly a customer feeder. Another of these feeders appears to supply a borefield, making it different from a typical rural feeder. The third, 22KP03 TINDAL 2, appears to supply a Royal Australian Air Force Base.

Given the unusual nature of these feeders, we do not see this result as a reason to modify our recommended approach. However, it underscores the importance of retaining a discretionary element in the final approach to feeder categorisation. Therefore, our final recommendation is that the 162 feeders for which a full set of data was provided should be categorised as per Table 8 (details for each feeder are in Appendix A):

Table 8 **Recommended feeder categories**

Feeder categorisation	Number of feeders
CBD	20
Urban (based on threshold)	68
Urban (based on location alone)	3
Rural Short	21
Rural Long	2
Mixed	9
<b>Subtotal</b>	<b>123</b>
Local Judgement	39
<b>Total</b>	<b>162</b>

Figures 6, 7, 8 and 9 provide maps showing the effect of re-categorising the regulated networks using a threshold of 0.12 MVA/km. Feeders that were categorised as rural under the standard SCONRRR approach and are categorised as urban with this lower threshold are identified separately from feeders whose categorisation is not changed.

The figures show that, for the most part, when feeders are categorised using a threshold of 0.12 MVA/km to distinguish between urban and rural feeders, the urban areas of the Territory are supplied by feeders categorised as urban.

There is an area between Darwin and Palmerston where the feeder categorisation is varied (see Figure 6). Some feeders in this area are categorised



**ACIL Tasman**

Economics Policy Strategy


## **Independent review of distribution network feeder category definitions**

as urban and others rural. This may reflect the specific nature of this area, or it may be reason to examine the appropriate categorisation of these feeders more closely.

It is clear from the maps that a number of feeders for which a full set of data was not available, that is, those listed in Table 6, are in urban areas. As with the six mismatched feeders listed in Table 7 our recommendation is that these feeders be categorised based on the best available information as to where the customers they supply are located.



Figure 6 Darwin – recommended feeder categorisation and population density




Note: the urban (blue) feeder largely on its own in approximately the middle of the map is 11BE14 ROBINSON. The urban (blue) feeder continuing to the north of Palmerston is 11PA02 WALER. These were both originally categorised as Urban and remained so in our target categorisation.

Data source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)



Figure 7 Katherine – recommended feeder categorisation and population density




Note: the two Urban (red) feeders outside the urban area are 22KP04 KATH East (upper) and 22KP03 Tindal 2 (lower). The former is marked Urban because a significant portion of it is within the urban area. It has an MVA/km of 0.27, very close to the SCONRRR threshold. The latter is identified as a 'mismatched feeder' in Table 7.

Data source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)






Figure 8 Tennant Creek – recommended feeder categorisation and population density



Data source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)



Figure 9 Alice Springs – recommended feeder categorisation and population density



NOTE: the urban (red) feeder that extends off the map to the south is 22BR102 BOREFIELDS, see Table 7  
Data source: Power and Water Corporation (feeder categorisation) and Australian Bureau of Statistics 2011 census (population density)

## 6 Conclusion and recommendations

Based on the analysis presented above we have identified a number of preliminary recommendations for the Commission's consideration. The Commission should note that these recommendations might, if adopted, require PWC to make changes to its databases and other information systems. These recommendations are based, in part, on our expectation that it would be simpler for PWC to make some changes to its systems than others. However, these expectations have not been tested by PWC.

Our recommendations are:

- 1 That the Commission adopt the view that:
  - d) customers who are in *like* areas can reasonably expect to receive a similarly reliable supply of electricity; and
  - e) it is reasonable for the level of supply reliability to be different in different 'types' of area.
2. That, for these purposes, parts of the Territory supplied by the regulated networks can be divided into two types of areas, namely urban and rural and that the maps presented in this report are a reasonable approximation of where these types of areas are.
3. That the Commission adopt the view that:
  - a) the purpose of feeder categorisation in the draft Code is to provide a reasonable basis for regulating reliability of supply
  - b) alternative feeder categorisations may be adopted for other reporting purposes.
4. That, for the impending regulatory period:
  - a) it would be appropriate to use the standard SCONRRR definitions as a guide to feeder categorisation with the modification that the threshold for distinguishing between urban and rural feeders should be 0.12 MVA/km
  - b) in cases where this method leads to unintended or unacceptable categorisations, such as mixed feeders which run through urban areas into rural areas, those categorisations should be amended by agreement between PWC and the Commission based in part on PWC's detailed knowledge of the regulated networks
  - c) the column in Table A1 headed final recommendation should form the basis of feeder categorisations for the impending regulatory period. Feeders marked there as 'local judgement' should be categorised based on the nature and location of customers they supply
5. That, the objectives of the draft Code would be best served by preserving a degree of discretion over feeder categorisation by making decisions



**ACIL Tasman**

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

regarding feeder categorisation in the Commission's determinations rather than in the draft Code itself. In practice:

- a) the draft Code may indicate that feeder categorisation would be determined through the regulatory process
  - b) the regulatory determination, or associated documents, may specify the categorisation of each feeder.
6. That the Commission make a separate decision as to the basis, if any, on which it would require reliability of supply to be reported for the purpose of making comparisons with other jurisdictions.

## Appendix A Compiled feeder categorisations

Table A1 **Type table title here**

feeder	Initial categorisation (PWC)	Target categorisation	Categorisation at threshold of 0.12 MVA/km	Final recommendation
11AK03 AUSTIN LANE	CBD	CBD	CBD	CBD
11BE01 LEANYER	Rural Short	Urban	Urban	Urban
11BE03 TDZ	Rural Short	Urban	Urban	Urban
11BE04 MCMILLANS	Rural Short	Urban	Rural Short	Urban (based on location alone)
11BE06 KARAMA 1	Rural Short	Urban	Urban	Urban
11BE07 NAVY	Urban	Urban	Urban	Urban
11BE08 BEZSS BUSTIE 1/2	Rural Short	Urban	Incomplete data	Local Judgement
11BE09 JAIL	Rural Short	Urban	Urban	Urban
11BE10 KARAMA 2	Urban	Urban	Urban	Urban
11BE11 BEZSS CAP BANK	Rural Short	Urban	Incomplete data	Local Judgement
11BE13 KORMILDA	Rural Short	Urban	Urban	Urban
11BE14 ROBINSON	Urban	Urban	Urban	Urban
11BE16 ANULA	Rural Short	Urban	Urban	Urban
11BE17 BEZSS BUSTIE 2/3	Rural Short	Urban	Incomplete data	Local Judgement
11BE18 PORT	Rural Short	Urban	Rural Short	Urban (based on location alone)
11BE21 BEZSS BUSTIE 3/4	Rural Short	Urban	Incomplete data	Local Judgement
11CA00 NIGHTCLIFF 1	Urban	Urban	Urban	Urban
11CA01 CA CAP NO 1	Rural Short	Urban	Incomplete data	Local Judgement
11CA01 CAZSS CAP BANK No 1	Rural Short	Urban	Incomplete data	Local Judgement
11CA03 BRADSHAW	Rural Short	Urban	Urban	Urban
11CA04 NTU	Urban	Urban	Urban	Urban
11CA06 FAC- LYONS	Rural Short	Urban	Urban	Urban
11CA07 JINGILI	Rural Short	Urban	Urban	Urban
11CA08 NORTH LAKES	Rural Short	Urban	Incomplete data	Local Judgement
11CA09 CAZSS BUSTIE 1/2	Rural Short	Urban	Incomplete data	Local Judgement
11CA10 MILLNER	Rural Short	Urban	Urban	Urban
11CA11 CAZSS CAP BANK No 2	Rural Short	Urban	Incomplete data	Local Judgement
11CA12 MARRARA	Urban	Urban	Urban	Urban
11CA13 WANGURI	Rural Short	Mixed	mixed	mixed
11CA15 HOSPITAL	Urban	Urban	Urban	Urban
11CA16 NAKARA	Rural Short	Urban	Urban	Urban



**ACIL Tasman**

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

feeder	Initial categorisation (PWC)	Target categorisation	Categorisation at threshold of 0.12 MVA/km	Final recommendation
11CA17 CAS SQUARE	Urban	Urban	Urban	Urban
11CA18 CAZSS BUSTIE 2/3	Rural Short	Urban	Incomplete data	Local Judgement
11CA19 CAS VILLAGE	Rural Short	Urban	Urban	Urban
11CA21 NIGHTCLIFF 2	Rural Short	Urban	Incomplete data	Local Judgement
11CA23 MOIL	Rural Short	Urban	Urban	Urban
11CA24 CAZSS BUSTIE 3/4	Urban	Urban	Urban	Urban
11CA25 BRINKIN	Urban	Urban	Urban	Urban
11CAZSS BUS 1	Rural Short	Urban	Incomplete data	Local Judgement
11CAZSS BUS 3	Rural Short	Urban	Incomplete data	Local Judgement
11CP4306 WAGAIT	Rural Short	Rural Short	Incomplete data	Local Judgement
11CP4307 BELYUEN	Rural Short	Rural Short	Incomplete data	Local Judgement
11CZ01 CZZSS CAP BANK No 2	CBD	CBD	CBD	CBD
11CZ02 WEST BENNETT 1	CBD	CBD	CBD	CBD
11CZ03 AUSTIN KNUCKEY 1	CBD	CBD	CBD	CBD
11CZ05 WOODS ST 1	CBD	CBD	CBD	CBD
11CZ06 MOTT ST 1	CBD	CBD	CBD	CBD
11CZ07 STUART PARK	Urban	Urban	Urban	Urban
11CZ08 CZZSS BUSTIE 1/2	CBD	CBD	CBD	CBD
11CZ09 AUSTIN KNUCKEY 2	CBD	CBD	CBD	CBD
11CZ10 MITCHELL ST 1	CBD	CBD	CBD	CBD
11CZ12 MOTT STREET 2	CBD	CBD	CBD	CBD
11CZ13 WEST BENNETT 2	CBD	CBD	CBD	CBD
11CZ14 GARDENS	Urban	Urban	Urban	Urban
11CZ16 WOODS ST 2	CBD	CBD	CBD	CBD
11CZ17 MITCHELL ST 2	CBD	CBD	CBD	CBD
11CZ19 CITY VALLEY	Urban	Urban	Urban	Urban
11CZ20 DINAH BEACH	Rural Short	Urban	Urban	Urban
11CZ21 CZZSS CAP BANK No 1	Rural Short	Urban	Incomplete data	Local Judgement
11CZZSS BUS 1	CBD	CBD	CBD	CBD
11CZZSS BUS 2	CBD	CBD	CBD	CBD
11CZZSS BUS 3	CBD	CBD	CBD	CBD
11FB09 WATERFRONT	Urban	Urban	Urban	Urban
11LG06 BRADSHAW	Urban	Urban	Urban	Urban
11LG07 ARALUEN	Urban	Urban	Urban	Urban
11LG13 ELDER	Urban	Urban	Urban	Urban



ACIL Tasman

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

feeder	Initial categorisation (PWC)	Target categorisation	Categorisation at threshold of 0.12 MVA/km	Final recommendation
11LG15 LARAPINTA	Rural Short	Urban	Urban	Urban
11LG16 BRAITLING	Urban	Urban	Urban	Urban
11ML09 DALY	CBD	CBD	CBD	CBD
11PA01 PAZSS BUSTIE 1/2	Rural Short	Urban	Incomplete data	Local Judgement
11PA02 WALER	Urban	Urban	Urban	Urban
11PA03 PALM SHOPS	Urban	Urban	Urban	Urban
11PA04 BAKEWELL	Rural Short	Urban	Urban	Urban
11PA06 PAZSS CAP BANK No 2	Rural Short	Urban	Incomplete data	Local Judgement
11PA07 GRAY	Urban	Urban	Urban	Urban
11PA08 GUNN	Urban	Urban	Urban	Urban
11PA09 TF T1	Urban	Urban	Urban	Urban
11PA10 DRIVER	Rural Short	Mixed	mixed	mixed
11PA11 FARRAR	Rural Short	Urban	Urban	Urban
11PA12 PAZSS AUX TF 1	Rural Short	Urban	Incomplete data	Local Judgement
11PA13 PAZSS BUSTIE 2/3	Rural Short	Urban	Incomplete data	Local Judgement
11PA14 PAZSS AUX TF 2	Rural Short	Urban	Incomplete data	Local Judgement
11PA15 MOULDEN	Rural Short	Urban	Urban	Urban
11PA16 PAZSS CAP BANK No 1	Rural Short	Urban	Incomplete data	Local Judgement
11PA17 THORNGATE	Rural Short	Urban	Urban	Urban
11PA18 WOODROFFE	Urban	Urban	Urban	Urban
11PA19 DURACK	Urban	Urban	Urban	Urban
11PA21 YARRAWONGA	Rural Short	Urban	Urban	Urban
11PA22 PALM CIVIC	Urban	Urban	Urban	Urban
11PA23 GEORGINA	Rural Short	Urban	Urban	Urban
11RG01 GAP	Urban	Urban	Urban	Urban
11RG02 GOLF COURSE	Urban	Urban	Urban	Urban
11RG06 SADADEEN	Rural Short	Urban	Urban	Urban
11RG07 HOSPITAL	Urban	Urban	Urban	Urban
11RG08 CBD	Urban	Urban	Urban	Urban
11RG19 NTHSTUHWY	Rural Short	Urban	Urban	Urban
11RG20 WILLS	Urban	Urban	Urban	Urban
11RG21 GILLEN	Rural Short	Urban	Urban	Urban
11SN01 FANNIE BAY	Rural Short	urban	Urban	Urban
11SN02 BAGOT	Rural Short	Urban	Rural Short	Urban (based on location alone)
11SN04 SNZSS CAP BANK No 2	Rural Short	Urban	Incomplete data	Local Judgement
11SN05 MARANGA	Rural Short	Urban	Urban	Urban
11SN07 BAYVIEW	Urban	Urban	Urban	Urban



ACIL Tasman

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

feeder	Initial categorisation (PWC)	Target categorisation	Categorisation at threshold of 0.12 MVA/km	Final recommendation
11SN10 GOYDER	Urban	Urban	Urban	Urban
11SN13 BISHOP	Urban	Urban	Urban	Urban
11SN14 COONAWARRA	Urban	Urban	Urban	Urban
11SN16 PARAP	Urban	Urban	Urban	Urban
11SN17 RAAF	Urban	Urban	Urban	Urban
11SN19 LUDMILLA	Urban	Urban	Urban	Urban
11SN20 SNZSS CAP BANK No 1	Rural Short	Urban	Incomplete data	Local Judgement
11WB01 PARLIAMENT	CBD	CBD	CBD	CBD
11WB08 WHARF PRECINCT	Urban	Urban	Urban	Urban
11WS03 DASHWOOD	CBD	CBD	CBD	CBD
11WS08 CULLEN	Urban	Urban	Urban	Urban
11WS11 KITCHENER	CBD	CBD	CBD	CBD
11YU04 No.1 FEEDER	Rural Short	Rural Short	Incomplete data	Local Judgement
11YU10 No.2 FEEDER	Rural Short	Rural Short	Incomplete data	Local Judgement
11YU17 No.3 FEEDER	Rural Short	Rural Short	Incomplete data	Local Judgement
22BR102 BOREFIELDS	Rural Short	Rural Short	Urban	mixed
22HD402 LAMBELLS	Rural Short	Rural Short	Rural Short	Rural Short
22HD403 MIDDLE POINT	Rural Short	Rural Short	Rural Short	Rural Short
22KP01 AUX TF 1	Rural Short	Rural Short	Incomplete data	Local Judgement
22KP03 TINDAL 2	Rural Short	Rural Short	Urban	mixed
22KP04 KATH EAST	Rural Short	Urban	Urban	Urban
22KP06 PINE CREEK	Rural Short	Rural Short	Rural Short	Rural Short
22KP07 MATARANKA	Rural Long	Rural Long	Rural Long	Rural Long
22KP11 OPS TIE	Rural Short	Rural Short	Rural Short	Rural Short
22KP12 FLORINA	Rural Short	Rural Short	Rural Short	Rural Short
22KP14 GORGE	Rural Short	Rural Short	Rural Short	Rural Short
22KP15 TINDAL 1	Rural Short	Rural Short	Rural Short	Rural Short
22KP17 AUX TF 2	Rural Short	Rural Short	Incomplete data	Local Judgement
22KP19 KATHERINE TOWN	Rural Short	urban	Incomplete data	Local Judgement
22MA02 BATCHELOR	Rural Short	Rural Short	Rural Short	Rural Short
22MA03 ADELAIDE RIVER	Rural Short	Rural Short	Rural Short	Rural Short
22MA04 NTP	Rural Short	Rural Short	Incomplete data	Local Judgement
22MA05 LAKE BENNETT	Rural Short	Rural Short	Incomplete data	Local Judgement
22MA07 ACACIA	Rural Short	Rural Short	Rural Short	Rural Short
22MM02 MMZSS CAP BANK	Rural Short	Rural Short	Incomplete data	Local Judgement
22MM05 HERBERT	Rural Short	Rural Short	Rural Short	Rural Short
22MM06 STRANGWAYS	Rural Short	Rural Short	Rural Short	Rural Short





**ACIL Tasman**

Economics Policy Strategy

## Independent review of distribution network feeder category definitions

feeder	Initial categorisation (PWC)	Target categorisation	Categorisation at threshold of 0.12 MVA/km	Final recommendation
22MM07 NOONAMAH	Rural Short	Rural Short	Rural Short	Rural Short
22MM09 MCMINNS PUMPS	Rural Short	Rural Short	Urban	mixed
22MM10 VIRGINIA	Rural Short	Rural Short	Rural Short	Rural Short
22MM11 DARWIN RIVER	Rural Short	Rural Short	Rural Short	Rural Short
22MM13 DUNDEE	Rural Short	Rural Short	Rural Short	Rural Short
22MR103 MT BUNDY	Rural Short	Rural Short	Rural Short	Rural Short
22MR303 TOMS GULLY	Rural Short	Rural Short	Incomplete data	Local Judgement
22PA101 HOWARD SPRINGS	Rural Short	Rural Short	Rural Short	Rural Short
22PC306 MOLINE	Rural Short	Rural Short	Incomplete data	Local Judgement
22PC308 PCK TOWNSHIP	Rural Short	Rural Short	Rural Short	Rural Short
22RG04 BREWER 2	Rural Short	Rural Short	Rural Short	Rural Short
22RG09 FARMS	Rural Short	Mixed	mixed	mixed
22RG13 BREWER 1	Rural Short	Mixed	mixed	mixed
22TC202 FEEDER 2	Rural Short	Rural Short	Rural Short	Rural Short
22TC302 FEEDER 3	Urban	Urban	Urban	Urban
22TC402 FEEDER 4	Rural Short	Urban	Incomplete data	Local Judgement
22TC502 FEEDER 5	Rural Short	Mixed	mixed	mixed
22TC602 FEEDER 6	Rural Long	Rural Long	Rural Long	Rural Long
CZ-CP	Rural Short	Rural Short	Incomplete data	Local Judgement
LOVEGROVE EXPRESS FDR 1	Rural Short	Urban	Incomplete data	Local Judgement
LOVEGROVE EXPRESS FDR 2	Rural Short	Mixed	mixed	mixed
PINE CK - COSMO HOWLEY	Rural Short	Rural Short	Incomplete data	Local Judgement

### **Melbourne (Head Office)**

Level 4, 114 William Street  
Melbourne VIC 3000

Telephone (+61 3) 9604 4400  
Facsimile (+61 3) 9604 4455  
Email [melbourne@aciltasman.com.au](mailto:melbourne@aciltasman.com.au)

### **Brisbane**

Level 15, 127 Creek Street  
Brisbane QLD 4000  
GPO Box 32  
Brisbane QLD 4001

Telephone (+61 7) 3009 8700  
Facsimile (+61 7) 3009 8799  
Email [brisbane@aciltasman.com.au](mailto:brisbane@aciltasman.com.au)

### **Canberra**

Level 2, 33 Ainslie Place  
Canberra City ACT 2600  
GPO Box 1322  
Canberra ACT 2601

Telephone (+61 2) 6103 8200  
Facsimile (+61 2) 6103 8233  
Email [canberra@aciltasman.com.au](mailto:canberra@aciltasman.com.au)

### **Perth**


Centa Building C2, 118 Railway Street  
West Perth WA 6005

Telephone (+61 8) 9449 9600  
Facsimile (+61 8) 9322 3955  
Email [perth@aciltasman.com.au](mailto:perth@aciltasman.com.au)

### **Sydney**

Level 20, Tower 2 Darling Park  
201 Sussex Street  
Sydney NSW 2000  
GPO Box 4670  
Sydney NSW 2001

Telephone (+61 2) 9389 7842  
Facsimile (+61 2) 8080 8142  
Email [sydney@aciltasman.com.au](mailto:sydney@aciltasman.com.au)



**ACIL Tasman**

Economics Policy Strategy

[www.aciltasman.com.au](http://www.aciltasman.com.au)